

# Test Report n. RTC14A017\_R00



## Test structure:



## Identification of the sample tested:

N°3 K7080 combined with door closer "Kontrol"


## Door panel:

900x2100mm, thickness 50mm

## Weight:

80Kg

## Hinges installation drawing:



## Durability test conditions:

- **Test mode:**  
continuous movements with 5" stop between open-closed cycles
- **Opening:**  
0-90° max
- **Scheduled cycles:**  
200.000

## Test result:

Cycles realized N° 200.000.  
At the end of the test K7080 hinges are in excellent an condition and functioning together with door closer "Kontrol" does not evidence any problems.

