

SUMMARY OF TESTED FIRE RESISTANCE

We hereby declare that on July, 29th, 2020, in the facility LGAI Technological Center, S.A. (APPLUS) Campus de la UAB. Ronda de la Font del Carme, s/n. 08193 Bellaterra - (Barcelona) (Spain), a fire door named X643* (DOOR C) has been tested according to EN 1634-1:2014+A1:2018. On November, 13th, 2020, the classification report 20/22763-1240-1 has been issued.

On the door has been incorporated the following hardware element:

Chronosoft 15x30*

Manufactured by:

C.C.E. srl*

Villa del Conte - Via dell'Artigianato, 16 - 35010 - (PD) - Italy

The door classified according to EN 13501-2:2016 as:

EI₁ 90

Category B

EI₂ 120

Category A

Signed on behalf of

LGAI Technological Center, S.A. (APPLUS)

Fire Laboratory Responsible



Digitally signed by
Albert Ger Castillo

CHEMOLLI FIRE

CEO

Eros Chemolli


CHEMOLLI s.a.s.
di Eros Chemolli & C.
Via Fitta, 1 - 38062 - Arco (TN)
C.F. , P.I./ VAT IT02261290221

Date of issue: 21 December, 2020

* This information has been provided by Chemolli Fire.