

Evidence of Performance

Electromechanically operated locks and striking plates according to EN 14846 : 2008



Test Report

No. 13-000827-PR01

(PB-G07-03-en-01)

Client Montajes Electrónicos
Dorcas S.L.
Calle de José Serrano, 6
46392 Siete Aguas, Valencia
Spain

Product Electromechanically operated strike plate

Designation 99-1 NDF TOP, 99-2 NDF, 99-2 NDF U2

Performance-relevant product details Symmetrical door opener, latchbolt radially opening, with manual release device
16 mm overall width
43 Ohm / 10-24 V

Maintenance According to maintenance instructions from the hardware manufacturer

Installation According to installation instructions from the hardware manufacturer

Special features

Basis

EN 14846 : 2008

Test standards:
EN 14846 : 2008

Equivalent national version
(e. g.. DIN EN)

Representation



Instructions for use

This test report serves to demonstrate conformity with the requirements for locks as per EN 14846 : 2008

Results

Classification according to EN 14846 : 2008

Category of use	Durability	Door mass and closing force	Suitability for use on fire/smoke doors	Safety	Corrosion resistance, temperature and humidity	Security	Security – electrical function	Security – electrical manipulation
3	X	5	0	-	L	0	0	2

This test report does not replace the EC Certificate of Conformity. Observe the provisions of EN 14846 : 2008 for marking and evaluation of conformity of construction products.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/ evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 26 pages.

ift Rosenheim

18.03.2015

Konrad Querengässer, Dipl.-Ing. (FH)
Head of Testing Department
Security/Safety Testing

Pascal Geiger, Dipl.-Ing. (FH)
Operating Product Officer
Building Components